



**MUNICIPAL CORPORATION OF DELHI
(PUBLIC HEALTH DEPARTMENT: CIVIL LINES ZONE)
16, RAJ PUR ROAD, DELHI – 110054**



DHO/CLZ/2026/892

Dated: 18/8/26

SCHOOL HEALTH CERTIFICATE


It is certified that an inspection team headed by public health inspector Civil Lines Zone from Public Health Department, inspected the **M/S Bud's Paradise School situated at Street No.-75, (Pusta Road) Sant Nagar, Delhi-110084** on 18.08.2026 and found that the school is running under sanitary and hygienic conditions from health point of view.

School has safe drinking water facilities for the students and members of staff of the institution and maintaining the hygiene and sanitation condition in the school building and the campus.


The above certificate is valid for 1 year from date of issue.

Manager,

**M/S Bud's Paradise School
at Street No.-75, (Pusta Road),
Sant Nagar, Delhi- 110084**



Dy. Health Officer
Civil Lines Zone

**Deputy Health Officer
Civil Lines Zone
Municipal Corporation of Delhi
16, Rajpur Road, Delhi-110054**





**DELHI JAL BOARD: GNCTD
ZONAL LABORATORY WAZIRABAD WATER
WORKS WAZIRABAD, DELHI-110054**



TEST REPORT

Ref. No.	DJB/DTQC/ZL/WZD/2026-27	Paid	106-107
Address of Sample	Bud's Paradise School, St. No. 75, Pusta Road, Sant Nagar, Delhi-110084		
Letter Reference No.	BPS/496/B/2026	Ref. Letter Date	17-08-2026
Challan No	125	Challan Date	17-08-2026
Sample Collection Date	18-08-2026	Analysis Start Date	18-08-2026
Any other Information		Analysis End Date	21-08-2026
UID of Report	4502	DJB/ZL/WZD/2026	4503
		Reporting Date	21-08-2026

S.N.	Particulars	Unit	Method	AS PER IS 10500		Inlet (Borewell)	RO
				Acceptable Limits	Permissible Limits in absence of alternate source		
1	Colour	CU	IS 3025 (P-4), 2021	5 (Max)	15 (Max.)	2	2
2	Odour	-	IS 3025 (P-5), 2018	Agreeable	Agreeable	AGREEABLE	AGREEABLE
3	pH Value at 25 °C	-	IS 3025 (P-11), 2022	6.5-8.5	No Relaxation	7.40	6.90
4	Turbidity	NTU	IS 3025 (P-10), 2023	1 (Max.)	5 (Max.)	1.0	0.72
5	Elec. Cond. at 25 °C	µS/cm	IS 3025 (P-14), 2013	-	-	1165	93
6	T.D.S.	mg/L	E.C. * 0.65	500 (Max.)	2000 (Max.)	757	60
7	Total Alkalinity as CaCO ₃	mg/L	IS 3025 (P-23), 2023	200 (Max.)	600 (Max.)	275	25
8	Total Hardness as CaCO ₃	mg/L	IS 3025 (P-21), 2009	200 (Max.)	600 (Max.)	420	40
9	Calcium as Ca	mg/L	IS 3025 (P-40), 2024	75 (Max.)	200 (Max.)	144	10
10	Magnesium as Mg	mg/L	IS 3025 (P-46), 2023	30 (Max.)	100 (Max.)	14	4
11	Chloride as Cl	mg/L	IS 3025 (P-32), 2025	250 (Max.)	1000 (Min.)	70	14
12	Sulphate as SO ₄	mg/L	IS 3025(Part-24)2022	200 (Max.)	400 (Max.)	87	14
13	Fluoride as F	mg/L	APHA 24th, 4500F-	1.0 (Max.)	1.5 (Max.)	0.70	0.20
14	Ammonical-N	mg/L	IS 3025(Part-34),1988	0.5 (Max.)	No Relaxation	BDL	BDL
15	Nitrate as NO ₃	mg/L	IS 3025 (Part-34),1988	45 (Max.)	No Relaxation	42.9	6.5
16	Iron	mg/L	IS 3025(Part-53),2003	1.0 (Max.)	No Relaxation	0.20	0.04
17	Residual Chlorine	mg/L	IS 3025 (Part-26), 2021	0.2 (Min.)	1.0 (Max.)	BDL	BDL
18	Coliform Count	MPN/ 100 ml		Absent	Absent	0	0

-----End of Report-----

*BDL= Below Detection Limit, Max. = Maximum, Min= Minimum

For the tested parameters Borewell water sample do not conforms specification for acceptable limit and can only be considered for drinking purpose in absence of better alternate source . RO water sample conforms specification and can be considered for drinking purpose.

[Signature]
Lab. Tech.

[Signature]
Asstt. Chemist

[Signature]
Bact.

[Signature]
Chemist 21/8/26

[Signature]
ACWA(WZD) 21/8/26

[Signature]
CWA(W&S)I

**Asstt. Chief Water Analyst
D.J.B. (Govt. of N.C.T. of Delhi)
Water Works, Wazirabad**